國立清華大學水質檢驗結果一覽表 National Tsing Hua University Water Quality Test Results Table							
編號 Number	受驗地點 check location	大腸桿菌群 colonic microbiota	採様日期 sampling date	檢測結果 detection results			
一、校本部 Main Campus							
1	大門口收費亭 Entrance Gate Toll Booth	<1					
2	工程一館動機系301 Department of Mechanical Engineering, Room 301, Engineering Building 1	<1					
3	化學館6F Chemistry Building 6F	<1					
4	化工館521 Chemical Industry Building 521	<1					
5	教育館3F靠旺宏館 Education Building 3F, next to Wanghong Hall	<1					
6	綜二館奈微所8F茶水間 Tea room on the 8th floor of Naiweishuo, Zhong 2 Building	<1					
7	綜三館理學院地下室茶水間 Tea room in the basement of the School of Science, Zhong 3 Building	<1					
8	台達館材料系B1-111休息室 Lounge B1-111, Department of Materials, Delta Building	<1					
9	台達館奈微所3F茶水間 Tea Room on the 3F, Naiwei Institute, Delta Building	<1					
10	台達館資工系6F茶水間 Tea room on the 6th floor of the Delta Building, Department of Finance and Economics	<1	111/06/08	符合規定 in compliance with			
11	清華會館8F Guest house 8F	<1		regulations			
12	綠能大樓4F Green Energy Building 4F	<1					
13	清華實驗室8F Tsinghua Laboratory 8F	<1					
14	清齋AB棟5F電梯前 In front of the elevator on 5F, Building AB, Chingzhai	<1					
15	清齋AB棟4F電梯前 In front of the elevator on 4F, Building AB, Chingzhai	<1					

16	清齋DE棟4F電梯前 In front of the elevator on 4F, Building DE, Chingzhai	<1				
17	清齋B棟2F洗衣間 Laundry room on 2F, Building B, Chngzhai	<1				
18	信齋C棟3F浴室 Shinn zhai Building C 3F Bathroom	<1				
19	信齋C棟2F浴室 Shinn zhai Building C 2F Bathroom	<1				
20	碩齋4F 402 Shuozhai 4F 402	<1				
21	碩齋4F 420 Shuozhai 4F 420	<1				
22	碩齋4F 436 Shuozhai 4F 436	<1				
23	善齋2F交誼廳 Shanzhai 2F Social Hall	<1				
	以下空白 Blank below					
二、南大校區 NTU campus						
1	行政大樓1F-教務處辦公室 Administrative Building 1F-Academic Affairs Office	<1				
2	竹師會館1F-樓梯口 Bamboo Master Building 1F-Stairway	<1		符合規定 in		
3	綜合教學大樓2F-前端茶水間 Comprehensive teaching building 2F- front tea room	<1	111/06/08	compliance with regulations		
4	教學大樓1F-圖說資料室 Teaching Building 1F-Illustration and Reference Room	<1				
	以下空白 Blank below					

註1.飲用水水質標準

Note 1. Drinking water quality standards.

大腸桿菌群colonic microbiota:6 (CFU/100mL)