

國立清華大學水質檢驗結果一覽表

National Tsing Hua University Water Quality Test Results Table

編號 Number	受驗地點 check location	大腸桿菌群 colonic microbiota	採樣日期 sampling date	檢測結果 detection results
一、校本部 Main Campus				
1	行政大樓 3F校規組前(右) Administrative Building 3F, in front of the School Regulations Section (right)	<1	111/11/16	符合規定 in compliance with regulations
2	科儀中心 2F Science and Technology Center 2F	<1		
3	體育館 119(左) Gym 119 (left)	<1		
4	風雲樓 3F Fengyun Building 3F	<1		
5	資電館資工系 320 Department of Information and Electronics Engineering 320	<1		
6	醫環系 404 Department of Biomedical Engineering and Environmental Sciences 404	<1		
7	工科館 1F WEF Engineering Building 1F WEF	<1		
8	工科館 4F 425 Engineering Building 4F 425	<1		
9	生科二館 1F大廳 Hall 1F , Life Science Building 2	<1		
10	生科二館 612 Life Science Building 2 612	<1		
11	台積館 3F廁所旁 Next to the toilet on 3F of TSMC Building	<1		
12	台積館 7F廁所旁 Next to the toilet on 7F of TSMC Building	<1		
13	清華實驗室 318 Tsinghua Laboratory 318	<1		
14	雅齋 5F 505 Yazhai 5F 505	<1		
15	雅齋 2F 228 Yazhai 2F 228	<1		
16	雅齋 2F 210 Yazhai 2F 210	<1		
17	雅齋 1F 122 Yazhai 1F 122	<1		

18	雅齋 1F 106 Yazhai 1F 106	<1		
19	雅齋 地下室 Yazhai basement	<1		
20	學齋 C棟5F Shiue Zhai Building C 5F	<1		
21	學齋 C棟4F Shiue Zhai Building C 4F	<1		
22	清齋 AB棟9F電梯前 In front of the elevator on 9F, Building AB, Chingzhai	<1		
23	清齋 DE棟2F電梯前 In front of the elevator on 2F, Building DE, Chingzhai	<1		
	以下空白 Blank below			
二、南大校區 NTU campus				
1	綜合教學大樓3F-前端茶水間 Comprehensive teaching building 3F-front tea room	<1	111/11/16	符合規定 in compliance with regulations
2	綜合教學大樓7F-茶水間 Comprehensive teaching building 7F-pantry	<1		
3	數理教育大樓5F-右側樓梯間 Mathematics and Physics Education Building 5F-stairwell on the right	<1		
4	推廣教育大樓2F-前端洗手間旁 Extension Education Building 2F-next to the front restroom	<1		
5	推廣教育大樓1F-英語教學系 Extension Education Building 1F-English Teaching Department	<1		
6	推廣教育大樓 6F Extension Education Building 6F	<1		
7	推廣教育大樓3F-計網中心 Extension Education Building 3F-Computer Network Center	<1		
	以下空白 Blank below			
<p>註1.飲用水水質標準 Note 1. Drinking water quality standards. 大腸桿菌群colonic microbiota : 6 (CFU/100mL)</p>				